



Gemeente  
Amsterdam

Amsterdam Zuidoost

**86057**

Inwoners

**6233**

Ondernemingen

**422876**

Ton CO2 per jaar

**92057**

Huishouden-  
equivalenten primair  
energiegebruik



# Data heat in Amstel III and the challenges.

Feasibility study Amstel III

[r.ruijtenbeek@amsterdam.nl](mailto:r.ruijtenbeek@amsterdam.nl)

[energietransitie@amsterdam.nl](mailto:energietransitie@amsterdam.nl)

25-10-2021


# Transition towards a sustainable city of Amsterdam

- Ambitions
- Sources of heat
- Challenges
  - Harvesting heat for the city and its citizens
  - Minimising impact electricity infrastructure
  - Maximising energy efficiency of datacenters
- Making it work
- What have we done so far ?
- And where are we now
- Your feedback: what lessons can we take back to Amsterdam?

# XXX NL-Laws and regulations

- VET Act (natural gas-free) - 1 July 2018
- Motion council, LT new construction - November 2017
- EPC 0.2 through crisis and recovery law 15 February 2019
- Vision BENG by Adam 1 jan 2021
- Building Decree: assessment of sustainability of residual heat sources -
  - Amsterdam Source book heat- January 1, 2020
  - Amsterdam Flex book electricity 1 June 2021
- BENG-NTA8800- January 1, 2021
- Heat Act 2.0 - January 1, 2022?
- Environment law – Juli, 2022? And BENG for A'dam?
- Fully circular National Goal 2050


## Energietransitie




## Klimaatverandering



## Circulaire economie



## Smart grid heat







# Smart city heating nets





## Target

- Fossilfree heating & cooling for the entire city in 2040
  - 483.000 housing equivalents existing city
  - 125.000 housing equivalents development


## Sources

- district heating (Vattenfall) – currently 90.000 housing equivalents
- aquathermal energy - under construction 5.000 housing equivalents
- utilisation heat datacenters – investigating pilots

# ✘ Existing heating district


✘ (110-120 °C – retour 70 °C / local 70-40 °C)

✘





# Aquathermal energy – surface water

(4 °C – 25 °C)



# ✘ Datacenters (20 °C – 35 °C)



Amsterdam - need for heat (2018 – 2040)

\* excluding isolation reduction measures

\* excluding industrial heat

= extra 4,7 PJ

Existing datacenters 0,5 – 1,7 PJ available

> challenge to connect source to user

Expected growth datacenter industry 1,6 PJ –

7,9 PJ (2018 – 2030)



> need to regulate growth (scalability & flexibility of electricity infrastructure)





# 'Our heat is available for free'

(says: the Dutch Datacenter Association in 2017 to minister of Economic Affairs)




Possible:  
50-100 %  
CO<sub>2</sub>  
reduction  
compared  
to gas

50 % CO<sub>2</sub> reduction  
compared to gas



# Reduction Co2

Heat plays an important goal in achieving climate goals - Total current energy demand built environment in Amsterdam



Bron: work in progress versie van City-zen Roadmap Amsterdam 2019, DDA Datacenters & Restwarmte 2021

Residual heat from data centers can play an important role in reducing CO<sub>2</sub> emissions in the built environment. 410 kton reduction is possible. That is 12% of the task of the NL Climate Table for the Built Environment. Source rapport Berenschot and IF Technology.

For gas this is approx. 57 kg CO<sub>2</sub>/GJ and district heating 32 kg CO<sub>2</sub> and data heat approx. 3 kg Co<sub>2</sub> when powered with wind energy.



Gemeente  
Amsterdam

# Making it work in South- East

1. Connecting to heating district
2. Connecting to local ATES
3. Connecting to building / consumer
4. Amstel III in South East Amsterdam
5. Building codes


# Sources Amstel III



- Existing heat and cold grid
- Synergy with construction assignment and sewer and street replacements
- Relatively more potential for peak reduction
  - » Data centers and ATEs sources
  - » Large peak reduction possible by integrating heat/cooling network
  - » Opportunities for battery storage, linking heat pumps, and EVs



# South east Amsterdam Energy neutral through cooperation



## PRAATPLAAT

### VISIE AMSTERDAM ZUIDOOST ENERGIENEUTRAAL 2040

Het is 2040:  
Amsterdam Zuidoost is energieneutraal. Er is een gezonde balans tussen de energie die verbruikt wordt om comfortabel te leven en de hoeveelheid duurzame opgewekte energie. De duurzame energie wordt opgewekt door diverse oplossingen. Een belangrijk uitgangspunt bij de ontwikkeling van deze wijk is dat de toekomstige bewoners optimaal wooncomfort krijgen tegen de laagste kosten en maximale bescherming van het milieu. Zuidoost profileert zich als de voorloper op het gebied van sociale energiebrandstijf.




- #### LEGENDA
- |  |   |  |                                       |
|--|---|--|---------------------------------------|
|  | Duurzame renovatie                        |  | Groengas                              |
|  | Duurzame bebouwing                        |  | Waterstof tankpaard / buffer          |
|  | Slaap / hernieuwbare energievoorziening   |  | Windturbine 3 MW                      |
|  | Daken PV en opwekkpunten                  |  | Geothermiebooring 2 km diep           |
|  | Onderstrooming                            |  | Groteschalige zonnepanelen 25 hectare |
|  | Warmte overdracht station                 |  | Circulaire HUB                        |
|  | Debaterratie en warmte overdracht station |  | Waste to energy met OAT               |
|  | Living Machine waterzuivering             |  | Mobiliteitshub                        |

## ENERGIEBALANS

Uit deze quickscan blijkt dat Amsterdam Zuidoost middels een forse investering in lokale energieopwekking en besparing energieneutraal kan worden.

Amsterdam Zuidoost produceert meer warmte dan het gebruikt. Dit komt door de warmte uit de datacenters (potentieel meer dan 4 PJ warmte). Het stadsdeel kan met dit overschot een bijdrage leveren aan de warmtevraag van andere stadsdelen.





# Energy savings in A'dam-SE

	Dataheat 4 DC's	BENG '21 PJ heat extr	GJ available houses	New data centers PJ max	BENG '19/21 houses
2020	0,65	0,39	19.500		
2025	1,2	0,9	45.000	1,3	65.000
<u>2030</u>	<u>1,65</u>	<u>1,3</u>	<u>65.000</u>	<u>1,8</u>	<u>90.000</u>
Total GJ	3,5	2,59		3,1	
Total new Houses	155.000		New build	47.000	


Approximately 1/3 heating and 2/3 tap water for BENG homes. Beng 2021: 50kwh/m2 BENG norm times 100m2 and then turn it into GJs. You come on approx. 20. For smaller homes it will also be less but not much of 2/3 tapwater. 1 gigajoule corresponds to about 35 to 40 m3 of gas. As a result of dry heating, consumption can increase by 10 to 30 gigajoules in the first year.

circulation of cool air ensures that the temperature remains constant between 25 degrees and 35 degrees.



Data centers: data in, data out, energy in, heat out. The energy consumption of data centers now consists of 99% electricity and is converted almost 1 to 1

the warm air heats water in the pipes. This heat is transferred to the heat network by a heat exchanger



racks are set up in data centers that use electricity and produce heat 24 hours a day



# Development Amstel III

- 🕒 15.000 appartements
- 🕒 3.000 - 4.500 apartment (< 2023)
- 🕒 2 districts: 3821, Paasheuvelweg en Urban District
- 🕒 1604 parkeerspaces (15% EV)
- 🕒 Commercial (8.333 m<sup>2</sup>)
- 🕒 Offices (47.266 m<sup>2</sup>)
- 🕒 Shops and others (20.704 m<sup>2</sup>)
- 🕒 Datacenters: AM9 en AM10 (55 & 25 MW)




(Re) development of office buildings and facilities

Limited capacity on the electricity network



# Future heat network in mixed area



**Figuur 3-1. Mogelijkheden om de transitie van bestaande HT-netten naar LT-netten in te vullen (1. naverwarmer, 2. gescheiden temperatuur zones, 3. aansluiting op HT-retourleiding en 4. cascadering)**





# Open heat,- and coldnetwork

## Datacenter


- currently, the residual heat in data centers is blown into the air by cooling machines. When connected to a cooling network, the data center receives a cold temperature of 12 degrees and supplies heat of approximately 30 degrees
- A heat exchanger (TSA) ensures that the data center circuit is separated from the distribution network
- The temperature who goes back to the datacenter approx -10 degree.

## Distribution network

- In the area, a distribution network is provided with both cold via ATES (WKO) of 12 degrees and data heat of 25 degrees
- This can be connected to the data center, ATES systems and buildings
- A TSA heat exchanger ensures that the circuit of the ATES systems is separated from the distribution network

## Buildings

- Buildings receive heat of approximately 25 degrees in winter and cold of 12 degrees in summer
- for tap water it is delivered at 25 degrees and this saves 1 heating level in the heat pump






Bron: Duurzame Ring Heerhugowaard, januari 2019  
Noot: geen ontwerp, slechts bedoeld ter illustratie

# Area with a mix of existing and new buildings

1.000-3.000 WEQ network

## Elektra

- Local electricity networks Energy
- Energy storage per sub-area
- Smart Grid lot- Smart Grid (DC or AC-DC)
- City -> Permits own network – LEN EU




## Heat /Cold

- Heat / cold Low temperature source networks
- Upgrading heat / cold per building
- Linking innovative techniques (H<sub>2</sub>).
- City -> Open market
- Cabels and pipes regulated
- Good quality buildings (isolation and installation)
- Data heat is possible Regeneration sources water,
- Preferably no dry coolers




# Aquifer Thermal Energy Storage (ATES)

Datacenter



Principe schema van een laag temperatuur distributienet met bronnen en restwarmte en -koude



Bron: Duurzame Ring Heerhugowaard, januari 2019  
Noot: geen ontwerp, slechts bedoeld ter illustratie



# Official documents

ATES interference area '21    ATES plan '22



Heat plan 1 '23



Heat plan 2 '24




# Impact different BENG-codes

- ⌚ Peak power **highly dependent** on heat / cold demand for **residential construction**
- ⌚ **Large differences** in peak between BENG standards for residential construction
- ⌚ **2019/2021 about 2x as high peak** as BENG 2015
- ⌚ BENG 2021 about **60-70% higher peak** than BENG 2015
- ⌚ New BENG Amsterdam EPC 0,2-> houses 60-20-70 (BENG<sub>1,2,3</sub>)
- ⌚ BENG standard is less significant for **offices and facilities**
- ⌚ as a result of a much more dominant peak consumption by equipment and lighting
- ⌚ Cold demand increasingly dominant (both peak and total) at lower BENG-1
- ⌚ In the case of LT + booster WPs, the largest peaks are expected.
- ⌚ Electric boilers will cause much larger peaks and can lead to problems





# Devellopments and governement rules



# Electra flex variants in this area



SIZE




www.ams-institute.org/urban-challenges/urban-energy/local-inclusive-future-energy-life-city-platform/




# Energy concepts from gas to the future


0: individual natural gas boiler -reference




1: Datacenter with LT-buffer



2: WKO/ATES with Datacenter regeneration



3: WKO/ATES with Aquathermal regeneration



4: Optional fourth system Biomass +20% natural gas/Diemen heat


5: Geothermal with 20% KEV for WP




# XXX Sustainable index

- From 2021 the electricity mix in NL will be more sustainable because the nationale electricity mix will be with more PV en Wind etc (KEV).

Development EOR energysystems in KEV (mix E-NL)




Development EOR energysystems in KEV (mix E-NL) + datacenter conversion efficiency





2. 6 lagen woningen, corridor,



# Results (Amsterdam buildingtype 2) Amstel III

## BENG RIJK 2021

## BENG A'dam 2022?

		Sc 1: Referentie (50% PV)	Sc 2: Referentie forfaitair (50% PV)	Sc3: Externe levering reguliere eis (50% PV)	Sc4: Externe levering reguliere eis (0% PV)	Sc5: Externe levering aangepaste eis (50% PV)	Sc6: Externe levering aangepaste eis (0% PV)
Indicator		Individuele WTP	Individuele WTP	Externe warmtelevering	Externe warmtelevering	Externe warmtelevering	Externe warmtelevering
CV	Fpdel	<i>nvt</i>	<i>nvt</i>	0,75	0,55	0,3	0,15
	Fpren	<i>nvt</i>	<i>nvt</i>	0,3	0,5	0,5	0,65
Tap	Fpdel	<i>nvt</i>	<i>nvt</i>	0,85	0,7	0,44	0,22
	Fpren	<i>nvt</i>	<i>nvt</i>	0,2	0,4	0,4	0,6
BENG 1		51,56	51,56	51,65	51,65	49,26	49,26
BENG 2		15,08	28,24	48,59	49,83	19,86	19,71
BENG 3		79%	63%	47%	42%	71%	71%

Volvoet aan reguliere eis
Volvoet aan aangepaste eis

On average 1/3 space heating and 2/3 tap water for NZEB homes  
Goal: to be at least 5% better than 40% BENG 3 – grow to BENG 3- 70%



- 4. Toren van 70 meter
- 5. Toren van 100 meter

4		Facade area for PV integration	<ul style="list-style-type: none"> <li>• High space need for installation</li> <li>• Less area for BIPV</li> <li>• Difficulties for airtightness and natural ventilation due to high wind speeds</li> </ul>
5			

## Results (Amsterdam buildingtype 4/5) Amstel III

### BENG RIJK 2021 BENG A'dam 2022?

		Sc 1: Referentie (1.962 m2 PV)	Sc 2: Externe levering reguliere eis (1.962 m2 PV)	Sc 3: Externe levering reguliere eis (geen PV)	Sc 4: Externe levering aangepaste eis (1.962 m2 PV)	Sc 3: Externe levering aangepaste eis (geen PV)
Indicator		Individuele WTP	Externe warmtelevering	Externe warmtelevering	Externe warmtelevering	Externe warmtelevering
CV	Fpdel	<i>nvt</i>	0,9	0,8	0,65	0,2
	Fpren	<i>nvt</i>	0	0,4	0,5	0,95
Tap	Fpdel	0,59	0,9	0,85	0,7	0,3
	Fpren	0,15	0	0,35	0,45	0,9
BENG 1		58,32	58,32	58,32	49,88	49,88
BENG 2		11,51	33,79	49,45	19,46	19,54
BENG 3		83%	51%	40%	70%	70%

Voldoet aan reguliere eis
Voldoet aan aangepaste eis

On average 1/3 space heating and 2/3 tap water for NZEB homes  
 Goal: to be at least 5% better than 40% BENG 3 – grow to BENG 3- 70%

# ✘ Issues too study

## ✘ 1. *Technical - financial*

- ✘ ■ Technology heating pumps
- Businesscase 3-4-5th gen.

## 2. *Governance*

- Contracts & collaboration
- Co-use electricity
- infrastructure DC (Tennet/Alliander)
- ATEs and dataheat combination

## 3. *Regulatory framework*

- Calculation EOR (SPF)
- Role government NL and City
- European framework
- Cooperation datacenter-sector
- Heat category NTA8800 datacenter


### Assumptions Amstel III:

- Heat network 3-4-5th generation (Amstel III)
- basic system 10.000m<sup>2</sup> building: WKO Beng '21 or more (with MT network to connect, current status 2019, municipality: 30°C (LT) and (70= MT)
- LT network + booster heat pumps: + 30% peak\*
- Data center residual heat: - 30% peak incl. WP air / water: + 50% peak (not included)
- Power factor: 0.85-0.9 MW / MVA (Liander)
- 3821 apartments
- Hot tap water preparation not simultaneously with space heating





# Questions ?





# Gemeente Amsterdam

[r.ruijtenbeek@amsterdam.nl](mailto:r.ruijtenbeek@amsterdam.nl)

[energietransitie@amsterdam.nl](mailto:energietransitie@amsterdam.nl)

# XXX SPOT 120 m



	Waarde	Toelichting
BENG 1 (kWh/m2/jr)	52	Toepassing triple glas Rc 4,5 - 4,5 - 6 qv = 0,25
BENG 2 (kWh/m2/jr)	7	WKO Balansventilatie Douche WtW
BENG 3 (%)	81	WKO, stadswarmte, PV



# Karspeldreef 14-16 115 m



	Waarde	Toelichting
BENG 1 (kWh/m2/jr)	47	Toepassing triple glas Rc 4,5 - 4,5 - 6 qv = 0,25
BENG 2 (kWh/m2/jr)	17	WKO Balansventilatie (Douche WtW of warmte delen met de buren)
BENG 3 (%)	71	WKO+ PV Data regeneratie (later)